



1 EU-TYPE EXAMINATION CERTIFICATE

- 2 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU
- 3 Certificate Number: Sira 13ATEX2257X
- 4 Equipment: Density/Viscosity Transmitter Types: HFVM, FVM, FDM.
- 5 Applicant: Micro Motion Inc.
- 6 Address: 7070 Winchester Circle AVE. Miguel de Cervantes Boulder Complejo Industrial Chihuahua Colorado. 80301 Chihuahua 31109 USA Mexico
- 7 This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

Issue:

1

Micro Motion Inc.

8 Sira Certification Service, notified body number 0518 in accordance with Articles 17 and 21 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN 60079-0:2012 EN 60079-1:2014 EN 60079-11:2012

The above list of documents may detail standards that do not appear on the UKAS Scope of Accreditation, but have been added through Sira's flexible scope of accreditation, which is available on request.

- 10 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to Specific Conditions of Use identified in the schedule to this certificate.
- 11 This EU-Type Examination Certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.
- 12 The marking of the equipment shall include the following:

II 1/2G Ex db IIC T6 Ga/Gb Ex db [ib] IIC T6 Ga/Gb Ta = $-40^{\circ}C \le Ta \le +65^{\circ}C$ Refer to Section 13 for additional marking information

n. Jones.

EN 60079-26:2007

N Jones Certification Manager

Sira Certification Service Unit 6 Hawarden Industrial Park,

Hawarden, CH5 3US, United Kingdom

inaman	
Tel:	+44 (0) 1244 670900
Fax:	+44 (0) 1244 681330
Email:	ukinfo@csagroup.org
Web:	www.csagroupuk.org

Project Number 70097935

This certificate and its schedules may only be reproduced in its entirety and without change.

Page 1 of 4





SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 13ATEX2257X Issue 1

DESCRIPTION OF EQUIPMENT 13

The Density/Viscosity Transmitter Types HFVM**, FVM** & FDM** are sensor combinations and are used for the measurement of fluid density and viscosity. They are also used to create I/O signals for data transmission. The transmitter and sensor together form a density or a viscosity meter. The fork transmitter is for use with the Micro Motion Fork Density Meter (FDM), Fork Viscosity Meter (FVM) and Heavy Fuel Viscosity Meter (HFVM). There are two styles of fork, 'Standard' and 'Long Stem'. The Long Stem version has a sealed tube connecting the fork/crystal assembly and the spigot/flame path, with the cable entering at the ends through Ex d cable glands. The standard fork and Long Stem crystal/fork assembly & spigot/flame path are filled with encapsulant to exclude the explosive atmosphere. The crystal/fork assembly is pressure-tested internally after welding. The maximum process temperature of the long stem is restricted by the limit of the cable glands used.

The electronic modules of these transmitters are mounted inside a universal aluminum or stainless steel enclosure. The enclosure uses the protection method Ex d. The electronic module consists of two boards, a power board and a microprocessor board; both are inserted into a plastic shell, which is filled with a potting material. There are two types of power board and one type of microprocessor board. Each board is identified with a colour.

When used with an intrinsically safe supply (such as the Micro Motion 2700 transmitter) using the power and RS485 terminals only, the interconnection is intrinsically safe (ib). The sensors may be installed in a zone 0 vessel across a zone 0/1 barrier.

Type Identification	Description	Marking
HFVM*******3F***** FDM*******3F***** FVM*******3F***** HFVM******B*2F***** FDM******B*2F***** FVM******B*2F*****	Fork Density Transmitter	Ex II 1/2 G Ex db IIC T6 Ga/Gb
HFVM*******A3F***** FDM******A3F***** FVM******A3F*****	Fork Transmitter (Connected to a remote transmitter type 2700**********)	II 1/2 G Ex db [ib] IIC T6 Ga/Gb

Table to define Type, Description and Marking for ATEX Equipment

Parameters of the Equipment Configurations

Types HFVM*******3F******, FDM*******3F*****, FVM*******3F***** Types HFVM******B*2F*****, FDM******B*2F*****, FVM******B*2F*****

Code: Ex db IIC T6 Ga/Gb

(Connector J1) Non Intrinsically safe main power supply. (Connector J5) Non Intrinsically safe RS485 communication port. (Connector J2) Non Intrinsically safe mA1 + HART communication port. (Connector J3) Non Intrinsically safe mA or DO or time period signal output communication port. Nominal Voltage 24V DC +10%

This certificate and its schedules may only be reproduced in its entirety and without change.

Sira Certification Service

Unit 6 Hawarden Industrial Park,

Hawarden,	CH5 3US,	United	Kingdom
-----------	----------	--------	---------

i iana	
Tel:	+44 (0) 1244 670900
Fax:	+44 (0) 1244 681330
Email:	ukinfo@csagroup.org
Web:	www.csagroupuk.org





SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 13ATEX2257X Issue 1

Types HFVM*******A3F*****, FDM*******A3F*****, FVM******A3F***** (ATEX)

Code: Ex db [ib] IIC T6 Ga/Gb

(Connector J1) Power Supply Circuit	
Voltage	Ui = 17.22V DC
Current	Ii = 484 mA
Power	Pi = 2.05 W
Maximum internal capacitance	Ci = Negligible
Maximum internal inductance	Li = Negligible
(Connector J5) RS 485 Circuit	
For connection of an intrinsically safe circuit (linear) with the f	following values:
Voltage	Ui = 17.22V DC
Current	li = 484 mA
Maximum internal capacitance	Ci = 1 µF
Maximum internal inductance	Li = Negligible
Voltage	Uo = 9.51V DC
Current (Instantaneous)	Io = 480 mA
Current (Steady State)	I = 106 mA
Power	Po = 786 mW
Internal resistance	Ri = 19.8 Ω
Maximum External Capacitance for Group IIC	Co = 85 nF
Maximum External Inductance for Group IIC	Lo = 25 µH
Maximum External Inductance/resistance ratio for Group IIC	$Lo/Ro = 31.1 \ \mu H/\Omega$

Variation 1 - This variation introduced the following changes:

- Addition of optional stainless steel housing to models HFVM, FVM and FDM, to form Types i. HFVM******B*2F******, FDM*******B*2F******, FVM*******B*2F****** Transmitters.
- Update of Standard EN 60079-1 to 2014. ii.

DESCRIPTIVE DOCUMENTS 14

14.1 Drawings

Refer to Certificate Annexe.

This certificate and its schedules may only be reproduced in its entirety and without change.

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom

	,	,
Tel:	+44 (0) 12	44 670900
Fax:	+44 (0) 12	44 681330
Email:	<u>ukinfo@cs</u>	agroup.org
Web:	www.csag	roupuk.org





SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 13ATEX2257X Issue 1

14.2 Associated Sira Reports and Certificate History

Issue	Date	Report number	Comment
0	03 February 2014	R30062A/00	The release of the prime certificate.
1	02 December 2016	R70097935A	This Issue covers the following changes:
			EC Type-Examination Certificate in accordance with
			94/9/EC updated to EU Type-Examination Certificate
			in accordance with Directive 2014/34/EU. (In
			accordance with Article 41 of Directive 2014/34/EU, EC Type-
			Examination Certificates referring to 94/9/EC that were in
			existence prior to the date of application of 2014/34/EU (20 April
			2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Variations to such EC Type-
			Examination Certificates may continue to bear the original
			certificate number issued prior to 20 April 2016.)
			The introduction of Variation 1.

- 15 SPECIFIC CONDITIONS OF USE (denoted by X after the certificate number)
- 15.1 For the application of the transmitter in an ambient temperature of less than -20°C suitable cable and cable entries or conduit entries certified for this condition shall be used.
- 15.2 If certified conduit entries are used for the connection of the transmitter enclosure, the associated stopping boxes shall be installed immediately at the enclosure.
- 15.3 After de-energizing, a delay of 5 minutes shall take place before opening the enclosure.
- 15.4 The fork may be manufactured from a non-conductive material; it must not be installed directly in any process where the surface might be charged by the rapid flow of non-conductive media and shall only be cleaned with a damp cloth.
- 15.5 Models F*M******A3F***** & HF*M******A3F***** can only be connected to a Micro Motion 2700 transmitter.
- 15.6 Any external heating or cooling source shall not exceed the process temperature limitations of -40°C to +200°C.

16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

17 CONDITIONS OF MANUFACTURE

- 17.1 The use of this certificate is subject to the Regulations Applicable to Holders of Sira Certificates.
- 17.2 Holders of EU-Type Examination Certificates are required to comply with the conformity to type requirements defined in Article 13 of Directive 2014/34/EU.
- 17.3 The partition wall shall be routinely tested to a pressure of 1.5 times the maximum process pressure for a period of 60 seconds. The test pass criteria are that there shall be no leakage or damage to the partition wall.

This certificate and its schedules may only be reproduced in its entirety and without change.

Sira Certification Service Unit 6 Hawarden Industrial Park,

Haward	len, CH5 3US, United Kingdom
Tel:	+44 (0) 1244 670900
Fax:	+44 (0) 1244 681330

ukinfo@csagroup.org

www.csagroupuk.org

Email:

Web:

Certificate Annexe

<u>sira</u>	CS Gro	A Sup
CERTIFICATION		

Applicant:	
Applicant	Micro Motion Inc.
Equipment:	Density/Viscosity Transmitter Types: HFVM**, FVM**, FDM**.
Certificate Number:	Sira 13ATEX2257X

Issue 0

Drawing	Sheets	Rev.	Date (Sira Stamp)	Title
EB-20021628	1 to 2	AA	04 Dec 13	Tower Dwg
EB-20021629	1 of 1	AA	04 Dec 13	Cover –Blind dwg
EB-20021631	1 to 2	AA	04 Dec 13	Housing dwg
EB-20021632	1 to 2	AA	13 Nov 13	Full Assy
EB-20022191	1 to 11	AA	13 Nov 13	Fork, Safety Description
EB-20022272	1 of 1	AA	13 Nov 13	Module Assy
EB-20022280	1 to 4	AA	13 Nov 13	Fork-BFCORE BOM
EB-20022282	1 to 4	AB	13 Nov 13	Fork-Power-Remote BOM
EB-20022536	1 to 4	AA	13 Nov 13	Fork-BFCORE PCB
EB-20022537	1 to 7	AA	13 Nov 13	Fork-BFCORE-Circuit
EB-20022538	1 to 4	AA	13 Nov 13	Fork-Power PCB
EB-20022539	1 to 5	AB	13 Nov 13	Fork-Power-Circuit Remote
EB-20023786	1 to 5	AA	13 Nov 13	Final Assembly
EB-20023788	1 to 4	AA	04 Dec 13	ATEX-Zn0-Zn1 Labels
EB-20023791	1 to 3	AA	22 Nov 13	Additional-RS-485 safety description

Issue 1

Drawing	Sheets	Rev.	Date (Sira stamp)	Title
EB-20029771	1 to 2	AA	11 Oct 16	APPVL ASSY SST
EB-20029772	1 of 1	AA	11 Oct 16	APPVL BLIND SST
EB-20029773	1 to 2	AA	11 Oct 16	APPVL HOUSING SST
EB-20029782	1 to 2	AA	11 Oct 16	APPVL DISPLAY SST
EB-20029868	1 to 9	AA	11 Oct 16	SAFETY DESC DENSVISC SST ENCLOSURE
EB-20022272	1 to 2	AB	11 Oct 16	MODULE ASSY
EB-20023788	1 to 4	AB	11 Oct 16	ATEX-Zn0-Zn1 LABELS
EB-20023789	1 to 4	AB	11 Oct 16	IECEx-Zn0-Zn1 LABELS

This certificate and its schedules may only be reproduced in its entirety and without change.

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom Tel: +44 (0) 1244 670900

	,	
Tel:	+44 (0) 12	44 670900
Fax:	+44 (0) 12	44 681330
Email:	<u>ukinfo@cs</u>	agroup.org
Web:	www.csag	roupuk.org