



Certificate / Certificat Zertifikat / 合格証

ASC 1301001 C005

exida hereby confirms that the:

Series 551 and 553 Pilot Operated Inline Spool Valves

**ASCO Numatics
Lucé, France**

Have been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-7

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFH/PFD_{avg} and Architecture Constraints
must be verified for each application**

Safety Function:

The Valve will move to the designed safe position when de-energized within the specified safety time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.

The manufacturer
may use the mark:




Revision 2.2 August 16, 2018
Surveillance Audit Due
April 1, 2019



ANSI Accredited Program
ISO/IEC 17065
PRODUCT CERTIFICATION BODY
#1004




Evaluating Assessor


Certifying Assessor

Certificate / Certificat / Zertifikat / 合格証

ASC 1301001 C005

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

PFH/PFD_{avg} and Architecture Constraints must be verified for each application

Systematic Capability :

These products have met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with these products must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2_H.

Applications

Series 551 & 553 Spool Valves	3/2, NC, De-energize To Trip (DTT) and 5/2 (DTT)
-------------------------------	--

IEC 61508 Failure Rates in FIT¹

Failure Category	λ_{SD}	λ_{SU}	λ_{DD}	λ_{DU}
3/2 Single, NC, DTT, <2W Coil	0	209	0	329
3/2 Single, NAMUR, NC, DTT, <2W Coil	0	304	0	378
3/2 Single, NF Operator, NC, DTT, 9-16 W Coil	0	572	0	316
3/2 Single, NAMUR, NF Operator, NC, DTT, 9-16 W Coil	0	666	0	365
3/2 Redundant, NC, DTT, <2W Coil	0	187	0	369
5/2 Single, DTT, <2W Coil	0	234	0	378
5/2 Single NAMUR, DTT, <2W Coil	0	256	0	432
5/2 Single, NF Operator, DTT, 9-16 W Coil	0	597	0	365
5/2 Single, NAMUR, NF Operator, DTT, 9-16 W Coil	0	618	0	419
5/2 Redundant, DTT, <2W Coil	0	197	0	418
Adder for Coils ² 9-16 Watts	0	299	0	0
Adder for Class H Coils 16-30 Watts	0	729	0	0

¹ FIT = 1 failure / 10⁹ hours

² Failure Rate Adders for other Coil Options available from ASCO

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: ASC 13/01-001 R003 V1 R4 (or later)

Safety Manual: V9629R8 (or later)

Series 551 and 553
Pilot Operated Spool
Valves



80 N Main St
Sellersville, PA 18960

T-061, V3R1